

PUBLIC NOTICE

Wastewater – Pretreatment Local Limits

The Hatfield Township Municipal Authority (HTMA) hereby serves notice to all users, including those located in surrounding jurisdictions that are serviced by HTMA, it has completed a new Headworks Analysis in order to re-evaluate its Local Limits in accordance with state and federal requirements (pre-approved by USEPA – Dec. 2023). HTMA intends to adopt revised Maximum Allowable Industrial Loadings (MAILs) to establish necessary limits for regulating discharges of certain process wastewater pollutants into its POTW located in Colmar. The concentrations cited below represent “end-of-process” daily average default limits for the pollutants listed. These “revised” limits are derived from the available loadings mentioned above and shall apply to all industrial and commercial users (IUs) discharging process wastewater for disposal. No IU shall discharge process wastewater pollutants in excess of the concentrations listed below without written permit from the HTMA.

<u>POLLUTANT</u>	<u>CONCENTRATION (mg/l)</u>
Arsenic	0.02
Cadmium	0.01
Chromium-Total	2.00
Copper	2.00
Lead	0.20
Mercury	0.0005
Nickel	0.25
Silver	0.30
Zinc	2.00
Phenols-Total	2.00
Methylene Chloride	0.20
Bis(2-ethylhexyl)phthalate	0.20

IUs currently regulated by permit will be notified directly of any proposed revisions to their existing pollutant loading allocations and permit limits resulting from this analysis. All limits are subject to revision pending final EPA review and approval. Persons interested in examining documents relevant to development of these limits may do so by appointment at the Hatfield Township Municipal Authority office, or via our website under the “Pretreatment” tab: www.HTMAsewer.com

Persons interested in submitting commentary regarding these limits may do so in writing no later than February 2, 2024. Address to:

Hatfield Township Municipal Authority
3200 Advance Lane – Colmar, PA 18915
Attention: Pretreatment Coordinator

